

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.202	69.4%	6.724	89.7%	6.7
Crooked Creek	1.9	1.063	55.9%	1.652	86.9%	7.1
Olde Sycamore	0.15	0.047	31.3%	0.047	31.3%	8.6
Tallwood	0.05	0.022	44.0%	0.022	44.0%	8.3
Grassy Branch	0.05	0.045	90.0%	0.046	92.0%	6.0

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	1	0.128
Engineering Plan Review	14	0.435
Sketch Plan Review	15	0.676
Totals	30	1.239

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	1	0.046
Engineering Plan Review	8	0.183
Sketch Plan Review	5	0.059
Totals	14	0.288